

33

STROBE LIGHTS AND FIRE ALARM HORNS SHALL BE CONNECTED TO EXISTING FIRE ALARM ZONE AS REQUIRED. SUBMIT REPORT AND VERIFICATION CERTIFICATE TO ENGINEER FOR REVIEW. REFER TO SRRS FOR MORE DETAILS. ALL FIRE ALARM SCOPE OF WORK SHALL BE PERFORMED BY BASE BUILDING AUTHORIZED FIRE ALARM CONTRACTOR (VIPOND). FOR BY PASSING THE F/A SYSTEM, CONTACT "APOLLO PROPERTY MANAGEMENT., ATTN: MR. WADE KIRKPATRICK – @ (613) 225-7969 ext. 243 (OFF.), wade@apolloomgt.com" ALL COSTS SHALL BE CARRIED BY THE ELECTRICAL CONTRACTOR AND INCLUDED IN THIS CONTRACT.